

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No 161-24.03.26

Dated: 24/3/26.

It is certified that an inspection team headed by Dr. Rutvij Acharya.....  
from **Urban Primary Health Centre, Pethapur, Gandhinagar** Inspected the **Ved School for Excellence**, run by **Karm Kelavani Trust** situated **Survey No. 1731, Pethapur-Randheja Road, Pethapur, Gandhinagar, Gujarat-382610** on **12.03.2026** and on the basis of Water Test Report (Attached) bearing no **4404** dated **20.03.2026** **District Laboratory, Gujarat Jalseva Training Institute, Gujarat Water Supply & Sewerage Board (Lab)** certified that the **Ved School for Excellence** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till 1/4/2027.....

Signature with Seal : [Signature].....

Name : Dr. Rutvij Acharya.....

Designation : M.O......

Name & Address of the Office / Department : 6 PMS Pethapur  
**MEDICAL OFFICER**  
**URBAN HEALTH CENTER**

**PETHAPUR**

To ,  
**Ved International School**  
**Oppt. Aashka Hospital, Sargasan,**  
**Gandhinagar, Gujarat-382421**



Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



## DISTRICT LABORATORY

Ground Floor, GJTI, G-Road, Sec-15, Gandhinagar

Test Report

Name &amp; Address of Customer:-

Ved School For Excellence

Pethapur-Randheja Road

Pethapur

Gandhinagar

Customer Reference No.:16-25/26

Sample Submitted by :Customer

Date of Sample Receipt :12-Mar-2026

Analysis Starting Date :13-Mar-2026

Analysis Completion Date :13-Mar-2026

Discipline:Chemical Testing,Group:Drinking Water

Test Report No.: 4404/2025-26

Date of Issue : 16-Mar-2026

Sample ID : 4404

Mode of Sample: Satisfactory

Main Source :Ground Water

Source :R.O. Water

Location :Ved School For Excellence

Village :Pethapur

Habitation :Pethapur

Taluka :Gandinagar

District :Gandinagar

Latitude :-

Longitude :-

Kindly find herewith the Analytical Results.

Sample Type : Drinking Water

Sr.No.	Parameter	Unit	Reference Method :	Analytical Value
1	Odour	-	IS : 3025 (Part 5) - 2018	Agreeable
2	Turbidity	NTU	APHA (24 th Ed.2023), Method: 2130 B	0.89
3	pH at 25°C	-	APHA (24 th Ed.2023) Method: 4500 H <sup>+</sup> B	8.02
4	Conductivity at 25°C	µS/cm	APHA (24 th Ed.2023) Method: 2510 B	350
5	Total Dissolved Solids	mg/l	APHA (24 th Ed.2023) Method: 2540 C	224
6	Total Hardness(as CaCO <sub>3</sub> )	mg/l	APHA (24 th Ed.2023) Method: 2340 C	148
7	Calcium (as Ca <sup>2+</sup> )	mg/l	APHA (24 th Ed.2023) Method: 3500 Ca+2 B	35
8	Magnesium (as Mg <sup>2+</sup> )	mg/l	APHA (24 th Ed.2023) Method: 3500-Mg+2 B	15
9	Chloride (as Cl <sup>-</sup> )	mg/l	APHA (24 th Ed.2023) Method: 4500-Cl - B	32
10	Sulphate (as SO <sub>4</sub> <sup>-2</sup> )	mg/l	APHA (24 th Ed.2023) Method: 4500-SO4-2 E	12
11	Nitrate (as NO <sub>3</sub> <sup>-</sup> )	mg/l	APHA (24 th Ed.2023) Method: 4500-NO3- B	1.20
12	Fluoride (as F <sup>-</sup> )	mg/l	APHA (24 th Ed.2023) Method: 4500-F - C	0.31
13	Total Alkalinity(as CaCO <sub>3</sub> )	mg/l	APHA (24 th Ed.2023) Method: 2320 B	88

This Report is issued under the following terms &amp; Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2<sup>nd</sup> Revision) limits.

Reviewed by:

Prachi Patel  
(Technical Manager)

Issued By:

Khyati Nayak  
(Quality Manager)  
Authorized Signatory

-----End of the Test Report -----

O.W.No. DL/GNR/ 4404/ of 2026, Dt. 16/3 /2026.

Ground Floor, GJTI, G-Road, Sec-15, Gandhinagar

E-mail: districtlabgandhinagar@gmail.com



Sr. No.	Parameter	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
1	Odour	Agreeable	Agreeable
2	Turbidity, NTU, Max	1	5
3	pH value	6.5 to 8.5	No relaxation
4	Conductivity at 25°C	-	-
5	Total Dissolved Solids, mg/l, Max	500	2000
6	Total Hardness (as CaCO <sub>3</sub> ), mg/l, Max	200	600
7	Calcium (as Ca), mg/l, Max	75	200
8	Magnesium (as Mg), mg/l, Max	30	100
9	Chloride (as Cl), mg/l, Max	250	1000
10	Sulphate (as SO <sub>4</sub> ), mg/l, Max	200	400
11	Nitrate (as NO <sub>3</sub> ), mg/l, Max	45	No relaxation
12	Fluoride (as F), mg/l, Max	1	1.5
13	Total Alkalinity (as CaCO <sub>3</sub> ), mg/l, Max	200	600



**DISTRICT LABORATORY**  
**GUJARAT JALSEVA TRAINING INSTITUTE**  
**GUJARAT WATER SUPPLY & SEWERAGE BOARD**  
**SECTOR - 15, 'G' Road, GANDHINAGAR - 382016**



**REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER**

**Name & Address:-**

Ved School For Excellence	Sender's Ref.No:	-
Pethapur-Randheja Road, Petha[pur	Date of Receipt at Lab. / Arrival Date:	12-Mar-26
Gandhinagar	Sample Collected By:	Sender

Lab Ref. i.e. BW No.	4484
Date of Collection	12-Mar-26
Date of Commencing Examination:	12-Mar-26
Source of Water Sample	R.O. Water
	Ved School For Excellence
Village	Pethapur
Habitation	Pethapur
Taluka	Gandhinagar
District	Gandhinagar
Membrane Filtration Method, IS-15185:2016, ISO 9308-1:2014 for Total Coliform	< 1
Membrane Filtration Method, IS-15185:2016, ISO 9308-1:2014 for Therotolerant Fecal Coliform ( <i>E.coli</i> )	< 1
Opinion For Potability As Per The BIS:10500:2012	Safe

**Important Note:-**

- \*Sample should be collected in sterile BOD bottle.
- \*"Unsafe" :- Proper Disinfection may render it safe.
- \*Presence of Coliform in water sample indicates the need of proper Disinfection.

**NOTE :**

Table - 6 Bacteriological Quality of Drinking Water (BIS:10500:2012) : Second Revision.

\*All Water Intended for Drinking -

(a) *E.coli* or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

\*Treated Water Entering the Distribution system & Treated Water in the Distribution system -


(a) *E.coli* or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.


(b) Total coliform bacteria shall not be detectable in any 100ml sample.

1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.

2) This Report should not be taken as a basis to getting license from any Government authority.

3) After Collection of Bacteriological sample, it must be preserved at (5±3)°C and submitted to laboratory within 24hrs.

Analysed By :   
Microbiologist

  
Lab Incharge

Outward No.: GJTI/Dist.Lab/BWT 4484 / of 2026, Date: 20 / 3 / 2026